



Z Control[®]



Z CONTROL



90002-0001

Connect Pivot[®] Pro
and LPS control
panels to the
Z Control[®] Cloud.



Wi-Fi Gateway



zoellerpumps.com | 800-928-7867 | 3649 Cane Run Rd., Louisville, KY 40211

Wi-Fi Gateway

Use the Wi-Fi Gateway to connect your Zoeller product (Pivot Pro and LPS control panels) to the ZControl® Cloud in just a few simple steps. Connecting to ZControl® allows the user to gain remote access to control and manage devices and to receive email, text, and push alert notifications and reminders.

Features:

- Simple set-up
- Automatically pairs with connected device
- Compact design (3.5" x 2.5" x 1")
- Lower cost than previous model
- Free standard access. No additional charge or subscription needed for standard ZControl® account access
- Includes 3' Cat5 cable and hook and loop fasteners for mounting
- Nema 1 enclosure (additional protection required for outdoor use)
- Connectivity LED and Reset button



[Back](#)

Pivot Pro

[Silence Alarms](#) [Reset](#) [Buzzer Test](#) [Share Device](#) [Delete Device](#)

[Status](#) [Alert History](#) [Device Settings](#) [Alert Settings](#) [Comments](#)

- ✓ Pump 1
 - ✓ Ready
 - ✓ Alarms Okay
- ✓ Pump 2
 - ✓ Next To Run
 - ✓ Alarms Okay
- ✓ HOA 1
 - ✓ Auto
- ✓ HOA 2
 - ✓ Auto
- ✓ Inputs
 - ✓ Stop Float

Last Updated: 12/7/2022 9:53:27 AM	
Device Name	Pivot pro on jas desk
Device Type	Pivot Pro
Device ID	2ATIEDIP9294C
Firmware Version	1.4
IP Address	192.168.5.103
Circuit Board Temperature	89.6 F*
Panel Operation Time	70 Days, 20 Hours, 32 Mins
System Time Since Last Reset	8 Days, 8 Hours, 32 Mins
Reset Count	194
Last Reset Cause	Startup
High Water Float Count	1
Run Mode	Duplex
Lead/Lag Select	Ratio
Lead/Lag Ratio	1 : 1
Pump 1 Cycle Count	12
Pump 1 Elapsed Run Time	39 Mins
Pump 1 Last Cycle Duration	8 Secs
Pump 2 Cycle Count	12
Pump 2 Elapsed Run Time	5 Mins
Pump 2 Last Cycle Duration	5 Secs

Benefits To User:

- Manage pump stations from your mobile device
- Supervise Pivot Pro and LPS control panels
- Remotely view cycle counts, elapsed time, pump modes and settings
- Change certain settings via mobile app or website.
- Silence active alarms, reset certain conditions
- Set up email, text, and push notifications for alarms and reminders

FM3393
0123
Supersedes
1121



All installation of controls, protection devices and wiring should be done by a qualified licensed electrician. All electrical and safety codes should be followed including the most recent National Electrical Code (NEC) and the Occupational Safety and Health Act (OSHA).