

Covered by US Patent Number 6,364,620

MAIL TO: P.O. BOX 16347 • Louisville, KY 40256-0347
 SHIP TO: 3649 Cane Run Road • Louisville, KY 40211-1961
 Tel: (502) 778-2731 • 1 (800) 928-PUMP

Visit our website:
 zoellerengineered.com

Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.



X71 HD HAZARDOUS LOCATION SERIES

CLASS I, DIVISION 1, GROUPS C & D

CLASS I, ZONE 1, GROUPS IIA & IIB

GRINDER PUMP GUIDE SPECIFICATIONS

3, 5 & 7-1/2 HP



1.01 GENERAL

Contractor shall furnish all labor, material, equipment and incidentals required to provide ____ (QTY.) cCSAus certified listed centrifugal grinder pump (s) rated for Class I, Division 1, Groups C or D and Class I, Zone 1, Groups IIA & IIB locations as specified herein.

2.01 OPERATING CONDITIONS

Each pump shall be rated at ____ HP, ____ Volts, ____ Phase, ____ Hz, 3450 RPM. The unit shall produce ____ GPM (LPM) at ____ ft (m) of TDH. The pump shall have a 2-1/2" flanged discharge adaptable to 3" and be capable of handling sanitary sewage and grinding it into a fine slurry enabling it to be pumped over long distances or high vertical lifts in pipelines as small as 2.00" (DN50) in diameter.

____ Optional 2" vertical NPT discharge; High Head and High Flow only.

3.01 CONSTRUCTION

The centrifugal grinder pump shall be equal to the Model ____ submersible type as manufactured by the Zoeller Engineered Products Company of Louisville, Ky. (800-928-7867) and listed by cCSAus for hazardous locations. The castings shall be constructed of baked on epoxy coated class 30 cast iron. The motor housing shall be finned and oil-filled to dissipate heat and enable the unit to operate unsubmerged without damage to the motor. Air-filled motors shall not be considered equal because of their inability to dissipate heat from the motor. All external-mating parts shall be machined and sealed with a buna-n square ring. All fasteners exposed to the liquid shall be 300 series stainless steel. The motor shall be protected on the top side with a sealed junction chamber which in the event of cord damage will prevent moisture wicking into the motor housing. The motor shall be protected on the lower side with a tandem mechanical seal arrangement with each seal having a separate spring assembly. The upper and lower ball bearings shall be capable of handling all thrust loads. The pump housing shall be of the concentric design thereby equalizing the pressure forces inside the housing, which will extend the service life of the seals and bearings. The top cap shall have cast in lifting lugs. The motor shall be protected by a moisture detection system, which will activate an alarm circuit if liquid is ever present in the upper junction chamber or lower seal cavity. Thermal sensors located in the oil-filled motor housing shall provide temperature protection.

____ As an option, provide the automatic reversing feature, available for flanged discharge 3 phase models, that enables the pump to grind in both CW and CCW direction. This feature prevents clogs and extends cutter life, which will prevent system downtime and extend the service life of the pump.

____ Optional viton square ring seals

4.01 ELECTRICAL POWER CORD

The pump shall be supplied with 25' (7.6 m) [____ 50' (15.2 m) optional] of multiconductor power cord. It shall be SOOW type cord capable of continued exposure to the pumped liquid. Power cord shall be sized for the rated full load amp rating of the pump in accordance with the National Electrical Code. Power cable shall enter into the junction chamber through a compression type-sealing gland. Water sealing and strain relief is separated. Each individual conductor shall be sealed against wicking should the cable become damaged. The entire junction chamber shall be sealed off from the motor housing. The junction chamber shall contain a set of moisture detection probes, activating an alert signal in the case of liquid entry.

5.01 MOTOR

The rated oil-filled motor with Class I, Division 1, Groups C and D and Class I, Zone 1, Groups IIA & IIB construction shall be a Class F insulated NEMA B design rated for hazardous location. At maximum load, the winding temperature will not exceed 250 °F (121 °C) unsubmerged. Since air-filled motors are not capable of dissipating heat, they shall not be considered equal. Start capacitors and relay for single phase models shall be mounted externally from the pump in a panel within 50 ft (15.2 m) of the pump location. Thermal sensors located in the oil-filled motor housing shall provide temperature protection.

6.01 BEARINGS AND SHAFT

Upper and lower ball bearings made of high carbon chromium steel shall be provided to prevent shaft deflection by withstanding all thrust and radial loads. The motor shaft shall be made of 416 SS and have a minimum diameter of 1.25" (381 mm).

7.01 SEALS

Pump shall have a dual mechanical seal configuration with the seals mounted in tandem. Each seal assembly having Silicon carbide / silicon carbide lower and carbon ceramic upper faces with Buna-N elastomer and 316 SS spring. It shall be equal to a Crane Type 21 configuration. Double seals with a common intermediate spring shall not be considered equal. The seal chamber shall contain a set of moisture detection probes, activating an alert signal in the case of liquid entry.

Optional seal faces shall be

___ Silicon carbide / Silicon carbide ___ Upper.

___ Silicon carbide / silicon carbide Viton ___ Lower / ___ Upper.

8.01 IMPELLER

The vortex impeller shall be a fully balanced ductile iron casting with pump out vanes on the back shroud to keep debris away from the seal area. It shall be keyed and bolted to the motor shaft.

8.02 CUTTER MECHANISM

The cutter and plate shall be constructed of 440 SS with a Rockwell C hardness of 55-60. The stationary cutter plate shall contain multiple machined orifices which enable the slurry to flow into the pump housing at an equalized pressure and velocity. The "star" cutter, rotating at 3450 RPM, shall shear all solids into a small particulate before passing through the orifices. Because of the extended service life of the "star" cutter, other cutter designs with tight clearances and those that grind on the circumference of the rotary plate shall not be considered equal.

9.01 PAINTING

The exterior castings of the pump shall be protected with a baked on epoxy powder coat paint.

As an optional feature include

___ Double epoxy coating protecting all internal and external wetted surface areas shall be required

10.01 SUPPORT

The pump shall have support legs enabling it to be a freestanding unit. The legs will be high enough to allow solids and long stringy debris to enter the cutter assembly.

For those installations requiring a field assembled rail system:

___ Non-sparking rail system with pump suspended by means of a sealed pump plate attached to the pump. Pump plate and guide rail shall be brass. Rail pipes to be provided by others.

___ SS intermediate stabilizer required for rail systems used where basin depths are greater than 20 ft (6 m)

11.01 TESTING

Each pump shall have a 20-30 minute operational test before shipment. It shall be checked at its maximum running point for performance, amps, grounding, winding insulation, and watertightness.

___ An optional certified test based on the Hydraulic Institute's or SWPA (Submersible Wastewater Pump Association) Test Standard for submersible pumps.

___ Start up services at the job site by an authorized representative of Zoeller Engineered Products Company shall be required. Start-up report form ZM1074 should be completed in the presence of the installers and returned to the Project Engineer or Zoeller Engineered Products Company.

12.01 WARRANTY

Standard warranty shall be 18 months from date of manufacture, 12 months from date of installation or 12 months from the date of start up with a start up report on file with Zoeller. Additionally, upon receipt and approval of a start up report, a prorated warranty for permanent municipal wastewater lift station installations shall be in effect for up to 60 months or 10,000 hours of operation, whichever comes first.



MAIL TO: P.O. BOX 16347 • Louisville, KY 40256-0347
SHIP TO: 3649 Cane Run Road • Louisville, KY 40211-1961
Tel: (502) 778-2731 • 1 (800) 928-PUMP

Trusted. Tested. Tough.®

visit our web site:
zoellerengineered.com