


Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.



# 71 & 72 HD SERIES MYERS RAIL ADAPTERS

Rail Adapter	Pump	Rail System Discharge
6039-0071	71 HD Series	2-1/2" Horz
6039-0126	72 HD Series	2-1/2" Horz

## INSTALLATION INSTRUCTIONS



zepa0510


## 10-0381 MYERS WA/WAL RAIL ADAPTER

### FOR 2 HP GRINDER PUMPS INSTALLATION INSTRUCTIONS

For your protection, always shut off the main power breaker and then disconnect the pump. Make sure you are wearing insulated protective sole shoes and not standing in water.

Pump upper guide and discharge plate are Myers castings and must be removed from old pump/piping to be reused.

1. Assemble 1-1/2" NPT x 6" nipple to Myers adapter.
2. Pull large power cord through adapter and nipple assembly.
3. Secure assembly to pump using supplied screws and washers.
4. Pull large power cord through upper guide bracket. Attach bracket with a set screw to the 1-1/2" nipple. Bracket may need to be repositioned vertically when piping is completed.
5. Plumb remaining piping using sketch provided as a reference. Be sure to use sealant on all threaded connections.



## HYDROMATIC HYDRO RAIL ADAPTER FOR 2 HP GRINDER PUMPS INSTALLATION INSTRUCTIONS

No extra charge to order pump with special retrofit pump housing.

